AXIS Fire Safety & Solution System

Marked Fire Fighting Equpment, Fire Alarm, Hydrant System, Electricals, School Bell, CCTV Cemera Excellent in Fire Protection & Maintenance



MSME.Lic.No.MP36D0011838.

GSTIN:-23BQHPR8783BIZL

CERTIFICATE

This is to certify that the fire extinguishers installed at the premises of M/s St.joseph sr.sec school Narsinghar Dist.Rajgarh (M.P.) is well conditioned and hytested to 30Kg/cm2 as per 2190, it has to be refilled and tested each and every year.

TYPE:-

Dry Powder (ABC store pesser) type fire extinguisher Refling Capacity- 04Kgs. - .6noes Dry powder (ABC store pesser) type fire extinguisher Refling Capacity- 02Kgs. - .4noes

Total Fire extinguisher = 10noes

TERMS:

- 1. Extinguisher should be operated by trained person.
- Extinguisher should not be exposed directly to sunlight or any direct Heat.
- 3. Extinguisher should be properly minted.
- 4. None operating or none functioning of extinguisher due to your negligence is not covered under this certificate.

REFILL DATE: - 02-07-2022 DUE DATE: :- 01-07-2023



